

DECATUR BATTERY ENERGY STORAGE FACILITY

Exhibit A-1.12 EMERGENCY OPERATIONS PLAN (FACILITIES WITH STORAGE ONLY)

Table of Contents

EXHIBIT A-1.12 – EMERGENCY OPERATIONS PLAN (FACILITIES WITH STORAGE ONLY)	2
---	---



EXHIBIT A-1.12 – EMERGENCY OPERATIONS PLAN (FACILITIES WITH STORAGE ONLY)

A-1.12.a – For energy storage projects, provide an Emergency Operations Plan in compliance with NFPA 855 (4.3.2.1.4).

An Emergency Operations Plan (EOP) in compliance with NFPA 855 (4.3.2.1.4) will be provided once the battery equipment for the Project has been purchased from the manufacturer. There is model specific information that the manufacturer will only provide at the time of purchase.

The EOP is designed to provide a structured framework for responding to fire or other emergencies, ensuring compliance with NFPA 855 standards while prioritizing the safety of personnel, first responders, and the environment. The plan applies to all individuals on-site, including personnel, contractors, and visitors. The emergency operations plan shall include clear procedures for safely shutting down, de-energizing, and restarting equipment after an emergency; inspecting and testing alarm systems; responding to system alarms; procedures in response to incidents such as fires, explosions, hazardous material releases, and equipment damage; response protocols similar to Safety Data Sheets (SDS); addressing damaged energy storage equipment; and conducting regular emergency drills with defined procedures and schedules.